

Sample Range Report

Fraser Health Authority

Facility Name: Patricia Hope House
Date Range: Jan 1 2024 to Dec 31 2024

Sampling Site	Date Collected	Total Coliform	E. Coli	Fecal Coliform
<u>Audit Kitchen tap</u>				
<u>treated water, 19465</u>				
<u>16th Ave</u>				
	5-27-2024 9:30:00 AM	<u>ESTCT 470</u> <u>ESTHCD</u>	<u>LT1</u>	
	Total Positive:	1	0	0
<u>Drinking Water</u>				
<u>Fountain, 19465</u>				
<u>16th Ave</u>				
	1-8-2024 9:25:00 AM	LT1 GTR200	LT1 GTR200	
	2-7-2024 9:52:00 AM	LT1	LT1	
	3-27-2024 1:05:00 PM	LT1	LT1	
	4-24-2024 12:30:00 PM	LT1	LT1	
	5-21-2024 11:00:00 AM	ESTCT 100 ESTHCD	LT1	
	5-27-2024 10:00:00 AM	ESTCT 430 ESTHCD	LT1	
	7-3-2024 10:00:00 AM	LT1 GTR200	LT1 GTR200	
	8-6-2024 12:19:00 PM	LT1 GTR200	LT1 GTR200	
	9-11-2024 11:30:00 AM	LT1	LT1	
	9-25-2024 12:30:00 PM	LT1 GTR200	LT1 GTR200	
	10-9-2024 1:30:00 PM	LT1	LT1	
	11-5-2024 8:00:00 AM	LT1 GTR200	LT1 GTR200	
	11-18-2024 1:30:00 PM	LT1	LT1	
	12-2-2024 9:00:00 AM	LT1	LT1	
	12-16-2024 1:00:00 PM	<u>LT1 GTR200</u>	<u>LT1 GTR200</u>	
	Total Positive:	2	0	0

Kitchen tap treated
water, 19465 16th
Ave

1-8-2024 9:27:00 AM	LT1 GTR200	LT1 GTR200	
2-7-2024 9:52:00 AM	LT1	LT1	
3-27-2024 1:05:00 PM	LT1	LT1	
4-24-2024 12:30:00 PM	LT1	LT1	
5-21-2024 11:00:00 AM	ESTCT 320 ESTHCD	LT1	
7-3-2024 10:00:00 AM	LT1 GTR200	LT1 GTR200	
7-15-2024 1:00:00 PM	LT1 GTR200	LT1 GTR200	
8-6-2024 6:00:00 PM	LT1	LT1	
8-28-2024 1:45:00 PM	LT1	LT1	
9-11-2024 11:30:00 AM	LT1	LT1	
9-25-2024 12:30:00 PM	LT1	LT1	
10-9-2024 1:30:00 PM	LT1	LT1	
11-5-2024 8:00:00 AM	LT1	LT1	
11-18-2024 1:30:00 PM	LT1	LT1	
12-2-2024 9:00:00 AM	LT1	LT1	
12-16-2024 1:00:00 PM	<u>LT1</u>	<u>LT1</u>	
Total Positive:	1	0	0

Tap Staff Lunch
Room, 19465 16th
Ave

1-8-2024 9:30:00 AM	LT1	LT1	
2-7-2024 9:52:00 AM	LT1	LT1	
3-27-2024 1:00:00 PM	LT1	LT1	
4-24-2024 12:30:00 PM	LT1	LT1	
5-21-2024 11:00:00 AM	ESTCT 190 ESTHCD	LT1	
5-27-2024 10:45:00 AM	ESTCT 400 ESTHCD	LT1	
7-3-2024 10:00:00	LT1 GTR200	LT1 GTR200	

AM		
7-15-2024 1:00:00	LT1 GTR200	LT1 GTR200
PM		
8-6-2024 6:15:00	LT1	LT1
PM		
8-28-2024 1:45:00	LT1	LT1
PM		
9-11-2024 11:30:00	LT1	LT1
AM		
9-25-2024 12:30:00	LT1 GTR200	LT1 GTR200
PM		
10-9-2024 1:30:00	LT1	LT1
PM		
11-5-2024 8:00:00	LT1	LT1
AM		
11-18-2024 1:30:00	LT1	LT1
PM		
12-2-2024 9:00:00	LT1	LT1
AM		
12-16-2024 1:00:00	<u>LT1</u>	<u>LT1</u>
PM		
Total Positive:	2	0

0

Result Values:

E - estimated

L - less than

G - greater than

Samples that contain total coliform:	6	12.24% of total
Samples that contain e. coli:	0	0.00% of total
Samples that contain fecal coliform:	0	0.00% of total
Number of consecutive samples that contain total coliform:	2	
Number of samples that contain total coliform in last 30 days:	0/3	
Total number of samples:	49	

Comments:

Environmental Health Officer

Jan 14 2025

FOR FURTHER INFORMATION PLEASE CALL: Barb Haworth